

EL DORADO COUNTY BUILDING DEPARTMENT
PERMIT REPRINT

APN #: 082-082-07-1 PERMIT #: 130446 - 1

PERMIT TYPE: MECHANICAL-NEW-SINGLE FAMILY (RESIDENTIAL)

SPECIFIC USE	TYPE	AREA	COST	VALUE
HEATING UNIT				3,500

PLANS

TOTAL: \$ 3,500

LEGAL DESCRIPTION: L 379

ZONING : R1
WATER SOURCE : EL DORADO IRRIG
NUMBER OF UNITS: 0

HEATING TYPE : ELECTRIC
SEWER SERVICE :
NUMBER OF BEDROOMS: 0

DATE ISSUED: 01/19/2001
DATE REACTIVATED:

DATE EXPIRES: 01/19/2003
DATE RENEWED:
DATE FINALED:

JOB ADDRESS: 3591 FAIRWAY DR

DIRECTIONS: MAP PAGE 29 C4; HWY 50 TO CAMERON PARK DRIVE TO SUDBURY
PLACE TO FAIRWAY DRIVE TO SITE

APPLICANT : COMFORT KING, INC
3867 DIVIDEND DRIVE
SHINGLE SPRINGS, CA 95682

(530) 676-2614

OWNER : WILDERMUTH ALLEN R
3591 FAIRWAY DR
SHINGLE SPRINGS, CA 95682

(530) 677-2896

ARCHITECT :

REG. # :

ENGINEER :

REG. # :

CONTRACTOR: COMFORT KING, INC

LICENSE: 553625

3
PT

ALL FRONT SETBACKS ARE
MEASURED FROM EDGE OF
ROAD EASEMENT.

T-99 FLOOD ZONE

"FUTURE" VENTED APPLIANCES
WILL REQUIRE A SEPARATE
PERMIT FOR INSTALLATION

60K BTU
New Furnace
(attic)

3/4" pipe

Future
Dryer
(22K)

Future Stove
& Oven conn.
(60K)

1" pipe

Ex.
Reg.

New
Reg.

APPROVED

Omissions & Errors on Plans
shall not be valid and all codes

JAN 19 2001

and Laws must be complied with

Insp. Permit # 130446

60,000 Furnace
TOTALS: 22,000 Dryer (future)
60,000 Stove/Oven (future)
147,000 BTU
Longest run 85'

250 Gal
Tank

130446

Jan. 17 2001 9:52AM P04

PHONE No. : 530 6759919

From : COMFORT KING Heating & A/C

El Dorado County
Planning Department

Approved by

JAN 19 2001

Plans comply with Zoning
Ordinances and Resolutions

CONDITIONS

PROP.
LINE

ALL FRONT SETBACKS ARE
MEASURED FROM EDGE OF
ROAD EASEMENT.

T-99 FLOOD ZONE

"FUTURE" VENTED APPLIANCES
WILL REQUIRE A SEPARATE
PERMIT FOR INSTALLATION

El Dorado County
Planning Department


Approved by

JAN 19 2001

Plans comply with Zoning
Ordinances and Resolutions

CONDITIONS

LPB/Talc



60,000 Furnace
TOTALS: 22,000 Dryer (future)
~~Stove~~
65,000 Stove/Oven (future)
147,000 BTU
Longest run 85'

APPROVED

Omissions & Errors on Plans
shall not be valid and all codes

JAN 19 2001

and Laws must be complied with

Insp

Permit # 130446

130446